



System S&P[®]
The Natural Wheel
Compact Module Sewage Plants



Altwigshagen

GERMANY

Altwigshagen

Design data	inlet	outlet
Size	300 PE	
Daily water flow	45 m ³ /d	
Peak flow	11,25 m ³ /h	
BOD	18 kg/d	≤ 40 mg/l
COD	36 kg/d	≤ 150 mg/l
TKN	3,3 kg/d	≤ 30 mg/l
T-P	0,54 kg/d	≤ 5 mg/l

Ø 2 m subsoil unit in PP tank

Type	1x STK-E-2.000-2.400/4-S
Disc surface	2.400 m ²
Lamella Separator	1x LMS-E-7/1
Date of manufacture	2009



System S&P GmbH

Ahornstraße 27
74592 Kirchberg an der Jagst

Fon +49 (0)7954 9804-0

Fax +49 (0)7954 9804-20

Mail info@system-s-and-p.de

Web www.system-s-and-p.de

