



System S&P[®]
The Natural Wheel
Compact Module Sewage Plants



Wollersleben

GERMANY

Wollersleben

| Design data | inlet | outlet |
|------------------|-----------------------|-----------|
| Size | 1.300 PE | |
| Daily water flow | 330 m ³ /d | |
| Peak flow | 33 m ³ /h | |
| BOD | 78 kg/d | ≤ 20 mg/l |
| COD | 156 kg/d | ≤ 90 mg/l |
| T-N | 14,3 kg/d | ≤ 50 mg/l |

Ø 2,5 m subsoil unit in PP tank

| | |
|---------------------|------------------------|
| Type | 4x STK-2.500-2.118/2-S |
| Disc surface | 8.472 m ² |
| Lamella Separator | 2x LMS-E-28/2 |
| Date of manufacture | 2010 |



System S&P GmbH

Ahornstraße 27
74592 Kirchberg an der Jagst

Fon +49 (0)7954 9804-0

Fax +49 (0)7954 9804-20

Mail info@system-s-and-p.de

Web www.system-s-and-p.de

