



**Hotel La Domaine
de L'Orangerie**

SEYCHELLES

Hotel La Domaine de L'Orangerie

Design data	inlet	outlet
Size	300 PE	
Daily water flow	60 m ³ /d	
Peak flow	6 m ³ /h	
BOD	18 kg/d	≤ 20 mg/l
COD	36 kg/d	≤ 80 mg/l
TSS	30 kg/d	≤ 30 mg/l
TKN	3 kg/d	≤ 20 mg/l

Ø 2 m above ground unit in PP tank

Type	1x STK-2.000-1.600/3
Disc surface	1.600 m ²
Lamella Separator	1x LMS-7/1
Date of manufacture	2008

System S&P GmbH

Ahornstraße 27
74592 Kirchberg an der Jagst

Fon +49 (0)7954 9804-0

Fax +49 (0)7954 9804-20

Mail info@system-s-and-p.de

Web www.system-s-and-p.de

